



Gilbert House
406 Roding Lane South
Woodford Green
Essex, IG8 8EY
United Kingdom

Job or Identification Number	PARIS C1 HX83	Date	14/07/2015 14:22
Location / Sample Designation	TEST ROOM	Operator	Ray Smith
		Temperature	18

Rz Surface Microroughness Readings

1	2	3	4	5	6	7	8	9	10	Mean

Pendulum Serial Number	1519	Calibration Date	26/05/2016 14:22
Slider Rubber Used	Slider 55 Slider 96	Level	0 Zero 0
Slider Preparation, P400 & lapping film	Green Pink		

Verification
readings (PTV)

lapping film test	55 , 60 , 59 / 60 , 60 , 59 , 59 , 59
float glass test	8 , 7 , 7 / 7 , 7 , 7 , 7 , 7
Pavigres tile test	36 , 36 , 35 / 35 , 35 , 35 , 35 , 34

Median
59
7
35

Floor Description	MATT TILE
Floor Condition	AS FOUND
	Slope 0

Pendulum Readings

Direction	Condition	Contamination	Readings	Median
FORWARD	WET	WATER	15 , 14 , 14 / 14 , 14 , 14 , 14 , 14	14
ACROSS	WET	WATER	15 , 15 , 15 / 15 , 15 , 15 , 15 , 15	15
DIAGONAL	WET	WATER	17 , 16 , 16 / 16 , 16 , 16 , 16 , 16	16
DIAGONAL	DRY	NONE	70 , 67 , 67 / 66 , 65 , 65 , 65 , 64	65
FORWARD	DRY	NONE	65 , 62 , 62 / 61 , 61 , 61 , 61 , 61	61
ACROSS	DRY	NONE	63 , 61 , 61 / 60 , 60 , 60 , 60 , 60	60